



July 11, 2002

Mr. Steve Neff
CGI/Silvercote, Inc.
29200 Fountain Pkwy
Solon, OH 44139

Dear Steve:

I am writing in response to your question regarding Skyweb II Safety Netting, specifically as it relates to the 400 pound OSHA drop test.

It is my understanding that some of your customers believe that this test needs to be conducted on every Skyweb II system prior to commencing the roofing process. This understanding is completely false; no testing of the Skyweb II system is required in the field. I can only imagine that there is some confusion between the Skyweb II System and perhaps some temporary nets or a system that has not previously passed the 400-pound test.

If you have any further questions, please don't hesitate to contact me at 816-968-3735.

Regards,
Butler Manufacturing Company

Harold Sanchez
Sky-Web Coordinator